



- NOTES:
1. Provide a min 1:100 and max 1:12.5 longitudinal fall to stormwater outlet. Refer to Drg. SD02-SD09 for outlet detail
 2. In high flow swales reinforced turf mats are to be installed to Manufacturer's specifications
 3. All pipe connections for drainage to be installed to Manufacturer's specifications
 4. On completion, test all subsoil drains by flushing with water to ensure system is free flowing

REVISIONS						
AMENDMENT	INITIALS	DATE		AMENDMENT	INITIALS	DATE
F			L			
E			K			
D			J			
C	Notes Altered		I			
B	Notes Altered		H			
A	ORIGINAL ISSUE		G			

IPSWICH CITY COUNCIL
 45 Roderick St
 P.O. Box 191
 Ipswich QLD 4305
 Australia

Tel (07) 3810 7894
 Tel (07) 3810 7927
 Fax (07) 3810 7950

APPROVED

 CHIEF OPERATING OFFICER (WPR)
 DATE 29-7-13

STANDARD DRAWING
**DRAINAGE - SURFACE MOUNDS AND SWALES
 IN GRASSED AREA**

PARKS
SP.15
 REV: C DRAWER: 100