


**NOTES:**

1. Protection Staking (optional)  
Stake trees with 2- 4 x stakes, 1800 x 50 x 50mm, driven 600mm into ground. Protection staking to prevent vehicle and/or slashers coming into contact with tree.
2. All services are to be verified before excavation of tree hole.
3. Any edging types around trees must be approved by ICC.
4. Supply and install non petroleum based soil-wetting agent or water crystals in accordance with Manufacturer's instructions
5. Soil wetting agent with fertiliser additive to be mixed through full depth of existing and imported topsoil.
6. Soil test to be carried out to determine if any amelioration works are necessary to improve the soils condition.
7. Where possible allow 2.5m min clear space around mulch collars for maintenance/mowing.
8. Tree holding system (above or below ground) should be put in place if required. System type must be approved by ICC.
9. If tree guards are required, type, style and location must be approved by ICC.

REVISIONS					
AMENDMENT	INITIALS	DATE	AMENDMENT	INITIALS	DATE
F				L	
E				K	
D				J	
C	Notes Altered			I	
B	Notes Altered			H	
A	ORIGINAL ISSUE			G	



**IPSWICH CITY COUNCIL**  
 45 Roderick St  
 P.O. Box 191  
 Ipswich QLD 4305  
 Australia

APPROVED  
  
 CHIEF OPERATING OFFICER (WPR)  
 DATE 29-7-13

**STANDARD DRAWING**  
 PLANTING - EX GROUND TREE  
 IN GRASSED AREA

PARKS  
 SP.06  
 REV: C DRAWER: 100